Water System Name: PWS ID No.: Arrow Point Community System 1280252 RE Date Collected: Collector: County: 03/14/2023 Kootenai Dean Renninger Report Results to: Arrow Point Community System Leslie Abrams 4502 S. Arrow Point Dr. Harrison, ID 83833 Fax: (208) 667-0745 Phone: (208) 667-0726 E-Mail: Leslie@gemstate-

water.com,pwsreports@deq.idaho.gov,cole@gemstatewater.com,lisa@gemstate-water.com,info@gemstate-

water.com

COLIFORM BACTERIA

ANALYSIS REPORT

CONTAMINANT ID# 3100

Type of System: Public

Type of Sample: Compliance Sample

Lab Order No.: 2023030197

Water system info must be fully filled out or samples will not be run. Private samples do not need PWS# or Chlorine residual. Your sample will be analyzed for TOTAL COLIFORMS unless you specify analysis under Remarks.

Laboratory Name:

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com

Lab EPA ID No: ID00912

For PWS only, if this is a repeat sample, mark the date of the ORIGINAL POSITIVE SAMPLE.

Sample Number	Sample Type	Sample Location	Time Collected	Chlorine Residual ppm	Original Sample Date	Total Coliform Method: 9223B-PA	E. Coli Method: 9223B-PA
252737	RS-Routine Sample	Office	08:50	0.38		Absent	Absent

Sample Transportation by (Name):	Dean Renninger	Date/Time:	03/14/2023 10:34	Analyst: ME	Date Analyzed: 03/15/2023
Sample Received by (Name):	JM	Date/Time:	03/14/2023 10:34	Supervisor: Rhena	a Cooper
Remarks:		Date Reviewed and Printed: 03/15/23			