Water System Name: Bitterroot Water Company		PWS ID No.: 1280260 RE
Collector: Zayne	Date Collected: 09/16/2024	County: Kootenai
Report Results to: Bitterroot Water Company Cole Rayner P.O. BOX 2306 Hayden, ID 83835		
Phone: (208) 651-7769	Fax:	
E-Mail: leslie@gemstate-	idaho gov cole@c	iemstate-

water.com,info@gemstate-water.com

COLIFORM BACTERIA

ANALYSIS REPORT

CONTAMINANT ID# 3100

Type of System:	Public
Type of Sample:	Compliance Sample
Lab Order No.:	2024090383

Water system info must be fully filled out or samples will not be run. Private samples do not need PWS# or Chlorine residual. Your sample will be analyzed for TOTAL COLIFORMS unless you specify analysis under Remarks. Laboratory Name:

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com

Lab EPA ID No: ID00912

For PWS only, if this is a repeat sample, mark the date of the ORIGINAL POSITIVE SAMPLE.

Sample Number	Sample Type	Sample Location	Time Collected	Chlorine Residual ppm	Original Sample Date	Total Coliform Method: 9223B-PA	E. Coli Method: 9223B-PA
273077	RS-Routine Sample	26736 N Clagstone	13:00			Absent	Absent

Sample Transportation by (Name):	Zayne	Date/Time:	09/16/2024 13:50	Analyst: RH	Date Analyzed: 09/17/2024
Sample Received by (Name):	JM	Date/Time:	09/16/2024 13:50	Supervisor: Rhena Cooper	
Remarks:			Date Reviewed and Printed: 09/17/24		