

Lab EPA ID No.: ID00912	Lab Sample#: 276536
Date Received: 12/10/2024	Date Reported by Lab: 12/12/24
Compliance or Replacement Sample: Compliance	
Date Collected: 12/09/2024	Time Collected: 14:05
Sample Type: Plant Tap	
PWS No.: 1280010 RE	PWS Name: Bar Circle S Ranch
Sampling Location: Well # 3	Tag#
Collector: Zayne	Phone: (208) 651-7769

Laboratory Name:
Accurate Testing Labs, LLC
 7950 Meadowlark Way
 Coeur d'Alene, ID 83815
 Phone (208) 762 8378
 Fax (208) 762 9082
 Web site: www.accuratetesting.com
 E-mail: info@accuratetesting.com

Lab Order No.: **2024120193** **3**

Public Drinking Water System INORGANIC CHEMICAL (IOC) ANALYSIS REPORT:

Phase II								Phase V							
FRDS	Analytes	Results	MCL*	MDL*	Method	Analysis Date	Analyst	FRDS	Analytes	Results	MCL*	MDL*	Method	Analysis Date	Analyst
1010	Barium							1036	Nickel						
1015	Cadmium							1074	Antimony						
1020	Chromium							1075	Beryllium						
1035	Mercury							1085	Thallium						
1038	NO2/NO3							Other IOCs							
1040	Nitrate-N	1.19	10.0	0.024	EPA 300.0	12/10/24	WM	1005	Arsenic						
1041	Nitrite-N							1025	Fluoride						
1045	Selenium							1052	Sodium						
1024	Cyanide														
Secondary IOCs (optional)															
1002	Aluminum							1055	Sulfate						
1003	Ammonia							1095	Zinc						
1016	Calcium							1905	Color						
1017	Chloride							1915	Hardness						
1022	Copper							1920	Odor						
1027	Hyd. Sulfide							1925	pH						
1028	Iron							1926	Conductivity						
1031	Magnesium							1927	Alkalinity						
1032	Manganese							1930	Diss. Solids						
1042	Postassium							1997	Langlier Indx						
1049	Silica SiO2							2905	Surfactants						
1050	Silver							1030	Lead						

*Reported in mg/L unless otherwise noted, units differ for secondary MCLs depending on contaminant
 ND = Not detected within sensitivity of instrument
 Empty = No analysis performed for this contaminant
 MDL = Method detection limit
 MCL - Maximum Contaminant Level

Comments:

Bar Circle S Ranch

P.O. Box 3388
 Coeur d'Alene, ID 83816



Laboratory Supervisor

Digitally signed by:
 Walter Mueller

12/12/24