

Anatek Labs, Inc.

Anatek Moscow - 1282 Alturas Drive - Moscow, ID 83843 - 208-883-2839 - moscow@anateklabs.com - FL NELAP E87893
Anatek Spokane - 504 E Sprague Ste. D - Spokane, WA 99202 - 509-838-3999 - spokane@anateklabs.com - FL NELAP E871099
Anatek Yakima - 4802 Tieton Drive - Yakima, WA 98908 - 509-225-9404 - yakima@anateklabs.com - FL NELAP E871190
Anatek Wenatchee - 3019 Gs Center Rd - Wenatchee, WA 98801 - 509-701-8362

Client: Pelican Point
Address: PO Box 3388
Coeur d Alene, ID 83816
Attn: Leslie Rayner

Work Order: WFE1029
Project: Bacteria
Reported: 5/22/2025 09:51

Analytical Results Report

System ID# **66800** System Name: **Pelican Point**
Reference Number: **WFE1029-01** Collect Date: **05/20/25 14:05** County: **Grant**
DOH Source #: Sample Type: **PT/F** Multiple Source Nos:
Matrix: **Drinking Water** Composition: **D00 - Coliform samples**
Date Received: **05/21/25 08:05** Sample Purpose: **RC - Routine/Compliance Sample**
Sample Location: **FH PP D8**

Lab/Sample Number: 112-02901

Coliform Bacteria

DOH #	Analyte	Result	Units	LRL	SDRL	Trigger	MCL	Analyzed	Analyst	Method	Qualifier
0001	Total Coliform	Absent		1.00	1	1	1	5/22/25 8:55	KCG	SM 9223 B	
0003	E. coli	Absent		1.00	1	1	1	5/22/25 8:55	KCG	SM 9223 B	

Anatek Labs, Inc.

Anatek Moscow - 1282 Alturas Drive - Moscow, ID 83843 - 208-883-2839 - moscow@anateklabs.com - FL NELAP E87893
Anatek Spokane - 504 E Sprague Ste. D - Spokane, WA 99202 - 509-838-3999 - spokane@anateklabs.com - FL NELAP E871099
Anatek Yakima - 4802 Tieton Drive - Yakima, WA 98908 - 509-225-9404 - yakima@anateklabs.com - FL NELAP E871190
Anatek Wenatchee - 3019 Gs Center Rd - Wenatchee, WA 98801 - 509-701-8362

Client: Pelican Point
Address: PO Box 3388
Coeur d Alene, ID 83816
Attn: Leslie Rayner

Work Order: WFE1029
Project: Bacteria
Reported: 5/22/2025 09:51

Analytical Results Report


System ID# **66800** System Name: **Pelican Point**
Reference Number: **WFE1029-02** Collect Date: **05/20/25 14:30** County: **Grant**
DOH Source #: Sample Type: **PT/F** Multiple Source Nos:
Matrix: **Drinking Water** Composition: **D00 - Coliform samples**
Date Received: **05/21/25 08:05** Sample Purpose: **RC - Routine/Compliance Sample**
Sample Location: **PPFH 54**

Lab/Sample Number: 112-02902

Coliform Bacteria

DOH #	Analyte	Result	Units	LRL	SDRL	Trigger	MCL	Analyzed	Analyst	Method	Qualifier
0001	Total Coliform	Absent		1.00	1	1	1	5/22/25 8:55	KCG	SM 9223 B	
0003	E. coli	Absent		1.00	1	1	1	5/22/25 8:55	KCG	SM 9223 B	

Authorized Signature,



Kelley Gee for Kathleen Sattler, Lab Manager

LRL Lab Reporting Limit
SDRL State Detection Reporting Limit
ND Not Detected
MCL EPA's Maximum Contaminant Level
Dry Sample results reported on a dry weight basis
SAL State Action Level
* Not a certified analyte

This report shall not be reproduced except in full, without the written approval of the laboratory
The results reported related only to the samples indicated.